



20-21 Wagaraw Road – Bldg. 35E, Fair Lawn, NJ 07410
PH (973) 636-9145 FAX (973) 636-9144
Email: Envirovision@optonline.net

CLIENT: Elmwood Park Public Schools Project Number 21-357
PROJECT: Lead (Pb) in Water Sampling Elmwood Park Memorial HS/MS/CC
ADDRESS: 375 River Drive, Elmwood Park NJ 07407
FIELD TECHNICIANS: Jordan Pryske REPORT DATE: September 17, 2021

As per your request, EnviroVision Consultants, Inc. was contracted by Elmwood Park Public Schools to conduct Lead (Pb) in water sampling at the Elmwood Park Memorial High School/Middle School (including the Career Center) on August 19, 2021. The sample locations, in addition to a unique sample location code was determined/assigned by school district personnel. The school district performed the proper flushing of outlets prior to sampling and EnviroVision was instructed to collect only first draw samples for this sampling event. The school district's corresponding flushing logs should be attached to this report.

The facility was closed at the time of sampling in order to prevent occupants from utilizing any water outlets. After flushing, the water in the facility must remain motionless in the plumbing fixtures for a minimum of 8 hours, but no more than 48 hours. Cold water samples were collected in pre-cleaned high-density polyethylene (HDPE) 250mL wide mouth bottles.

Samples were analyzed at EMSL Analytical, Inc. in Cinnaminson, New Jersey *(NJDEP#03036), accredited in accordance with NELAC (National Environmental Laboratory Accreditation Conference). The analytical method utilized was inductively coupled plasma mass spectrometry ICP-MS (EPA 200.8).

A total of 24 samples were collected from the Elmwood Park Memorial High School/Middle School/Career Center. An additional field blank was collected and analyzed, as required.

Results: All of the samples analyzed were either "None Detected" or less than the US EPA established threshold for lead in drinking water. When a water outlet/faucet meets or exceeds the USEPA threshold, EnviroVision recommends that the outlet/faucet be immediately put out of service until the system can be further evaluated and proper remedial action is achieved.



Page 2 (Elmwood Park Memorial HS/MS/Career Center) Project Number 21-358

Should you have any questions, or if we could be of any further assistance, please feel free to contact our office. EnviroVision looks forward to providing you with the service and attention to detail you have come to expect from us.

Sincerely,
EnviroVision Consultants, Inc.

Cathy DiNardo

Cathy DiNardo, Project Manager
Attached: Lab Results, Associated Data Sheets



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn:

**Bazhena Tulchinskiy
EnviroVision Consultants, Inc
20-21 Wagaraw Rd
Bldg 35E
Fair Lawn, NJ 07410**

9/13/2021

Phone: (973) 636-9145

Fax: (973) 636-9144

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 8/23/2021. The results are tabulated on the attached data pages for the following client designated project:

Elmwood Park Memorial HS/MS

The reference number for these samples is EMSL Order #012109765. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

Phillip Worby, Environmental Chemistry
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.

NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012109765
 CustomerID: RAMA51
 CustomerPO:
 ProjectID:

Attn: **Bazhena Tulchinskiy**
EnviroVision Consultants, Inc
20-21 Wagaraw Rd
Bldg 35E
Fair Lawn, NJ 07410

Phone: (973) 636-9145
 Fax: (973) 636-9144
 Received: 8/23/2021 09:00 AM

Project: **Elmwood Park Memorial HS/MS**

Analytical Results

Client Sample Description EH18U
 Old Gym (Main) **Collected:** 8/19/2021 6:15:00 AM **Lab ID:** 012109765-0001

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

METALS

200.8	Lead	ND	1.00 µg/L	9/9/2021 VD	9/9/2021 17:30 VD
-------	------	----	-----------	-------------	-------------------

Client Sample Description EH18L
 Old Gym (Main) **Collected:** 8/19/2021 6:15:00 AM **Lab ID:** 012109765-0002

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

METALS

200.8	Lead	ND	1.00 µg/L	9/9/2021 VD	9/9/2021 17:35 VD
-------	------	----	-----------	-------------	-------------------

Client Sample Description EH17U
 Aux Gym **Collected:** 8/19/2021 6:25:00 AM **Lab ID:** 012109765-0003

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

METALS

200.8	Lead	ND	1.00 µg/L	9/8/2021 KG	9/9/2021 13:36 JW
-------	------	----	-----------	-------------	-------------------

Client Sample Description EH17L
 Aux Gym **Collected:** 8/19/2021 6:25:00 AM **Lab ID:** 012109765-0004

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

METALS

200.8	Lead	ND	1.00 µg/L	9/9/2021 VD	9/9/2021 17:36 VD
-------	------	----	-----------	-------------	-------------------

Client Sample Description EH12
 Fountain **Collected:** 8/19/2021 6:27:00 AM **Lab ID:** 012109765-0005

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

METALS

200.8	Lead	ND	1.00 µg/L	9/9/2021 VD	9/9/2021 17:37 VD
-------	------	----	-----------	-------------	-------------------

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012109765
 CustomerID: RAMA51
 CustomerPO:
 ProjectID:

Attn: **Bazhena Tulchinskiy**
EnviroVision Consultants, Inc
20-21 Wagaraw Rd
Bldg 35E
Fair Lawn, NJ 07410

Phone: (973) 636-9145
 Fax: (973) 636-9144
 Received: 8/23/2021 09:00 AM

Project: **Elmwood Park Memorial HS/MS**

Analytical Results

Client Sample Description EH12B
 Bottle Filler
Collected: 8/19/2021 6:27:00 AM
Lab ID: 012109765-0006

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	9/9/2021 VD	9/9/2021 17:39 VD

Client Sample Description EH19
 Ice Machine
Collected: 8/19/2021 6:29:00 AM
Lab ID: 012109765-0007

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	9/9/2021 VD	9/9/2021 17:40 VD

Client Sample Description EH13
 Fountain
Collected: 8/19/2021 6:31:00 AM
Lab ID: 012109765-0008

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.59	1.00 µg/L	9/9/2021 VD	9/9/2021 17:42 VD

Client Sample Description EH08
 Fountain
Collected: 8/19/2021 6:33:00 AM
Lab ID: 012109765-0009

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.50	1.00 µg/L	9/9/2021 VD	9/9/2021 17:43 VD

Client Sample Description EH05
 Upper Fountain
Collected: 8/19/2021 6:35:00 AM
Lab ID: 012109765-0010

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.27	1.00 µg/L	9/9/2021 VD	9/9/2021 17:47 VD

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012109765
 CustomerID: RAMA51
 CustomerPO:
 ProjectID:

Attn: **Bazhena Tulchinskiy**
EnviroVision Consultants, Inc
20-21 Wagaraw Rd
Bldg 35E
Fair Lawn, NJ 07410

Phone: (973) 636-9145
 Fax: (973) 636-9144
 Received: 8/23/2021 09:00 AM

Project: Elmwood Park Memorial HS/MS

Analytical Results

Client Sample Description EH06 Lower Fountain **Collected:** 8/19/2021 6:37:00 AM **Lab ID:** 012109765-0011

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.33	1.00 µg/L	9/9/2021 VD	9/9/2021 17:49 VD

Client Sample Description EH04 Upper Fountain **Collected:** 8/19/2021 6:39:00 AM **Lab ID:** 012109765-0012

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	9/9/2021 VD	9/9/2021 17:50 VD

Client Sample Description EH14 Lower Fountain **Collected:** 8/19/2021 6:41:00 AM **Lab ID:** 012109765-0013

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	9/9/2021 VD	9/9/2021 17:54 VD

Client Sample Description EH03 Kitchen Faucet Sink **Collected:** 8/19/2021 6:43:00 AM **Lab ID:** 012109765-0014

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.30	1.00 µg/L	9/9/2021 VD	9/9/2021 17:55 VD

Client Sample Description EH11 Fountain **Collected:** 8/19/2021 6:45:00 AM **Lab ID:** 012109765-0015

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	9/9/2021 VD	9/9/2021 17:57 VD

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012109765
 CustomerID: RAMA51
 CustomerPO:
 ProjectID:

Attn: **Bazhena Tulchinskiy**
EnviroVision Consultants, Inc
20-21 Wagaraw Rd
Bldg 35E
Fair Lawn, NJ 07410

Phone: (973) 636-9145
 Fax: (973) 636-9144
 Received: 8/23/2021 09:00 AM

Project: Elmwood Park Memorial HS/MS

Analytical Results

Client Sample Description EH11B
 Bottle Filler
Collected: 8/19/2021 6:45:00 AM
Lab ID: 012109765-0016

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	9/9/2021 VD	9/9/2021 17:58 VD

Client Sample Description EH15
 HS Office Sink
Collected: 8/19/2021 6:47:00 AM
Lab ID: 012109765-0017

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.54	1.00 µg/L	9/9/2021 VD	9/9/2021 18:00 VD

Client Sample Description EH16
 MS Office Sink
Collected: 8/19/2021 6:49:00 AM
Lab ID: 012109765-0018

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.22	1.00 µg/L	9/9/2021 VD	9/9/2021 18:04 VD

Client Sample Description EH01
 Fountain
Collected: 8/19/2021 6:51:00 AM
Lab ID: 012109765-0019

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.08	1.00 µg/L	9/9/2021 VD	9/9/2021 18:05 VD

Client Sample Description EH09
 Fountain
Collected: 8/19/2021 6:53:00 AM
Lab ID: 012109765-0020

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.06	1.00 µg/L	9/9/2021 VD	9/9/2021 18:07 VD

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012109765
 CustomerID: RAMA51
 CustomerPO:
 ProjectID:

Attn: **Bazhena Tulchinskiy**
EnviroVision Consultants, Inc
20-21 Wagaraw Rd
Bldg 35E
Fair Lawn, NJ 07410

Phone: (973) 636-9145
 Fax: (973) 636-9144
 Received: 8/23/2021 09:00 AM

Project: **Elmwood Park Memorial HS/MS**

Analytical Results

Client Sample Description EH10
Guidance Sink
Collected: 8/19/2021 6:55:00 AM
Lab ID: 012109765-0021

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.92	1.00 µg/L	9/9/2021 VD	9/9/2021 18:08 VD

Client Sample Description EH02
Fountain
Collected: 8/19/2021 6:58:00 AM
Lab ID: 012109765-0022

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	6.59	1.00 µg/L	9/9/2021 VD	9/9/2021 18:14 VD

Client Sample Description EH07
Fountain
Collected: 8/19/2021 7:01:00 AM
Lab ID: 012109765-0023

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	9/9/2021 VD	9/9/2021 18:21 VD

Client Sample Description EHB
Blank
Collected: 8/19/2021 7:10:00 AM
Lab ID: 012109765-0024

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	9/9/2021 VD	9/9/2021 18:22 VD

Client Sample Description EHCC01
Sink
Collected: 8/19/2021 8:20:00 AM
Lab ID: 012109765-0025

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	6.14	1.00 µg/L	9/9/2021 VD	9/9/2021 18:23 VD

Definitions:

- MDL - method detection limit
- J - Result was below the reporting limit, but at or above the MDL
- ND - indicates that the analyte was not detected at the reporting limit
- RL - Reporting Limit (Analytical)
- D - Dilution Sample required a dilution which was used to calculate final results

Environmental Chemistry Chain of Custody

EMSL Order Number / Lab Use Only

02109765

EMSL ANALYTICAL, INC.

Customer ID:		Billing ID:	
Company Name: EnviroVision Consultants		Company Name: EnviroVision Consultants	
Contact Name: Cathy DiNardo		Billing Contact: Barkera Tuchinsky	
Street Address: 20-21 Wagarew Road		Street Address: 20-21 Wagarew Road	
City, State, Zip: Fair Lawn, NJ, 07410		City, State, Zip: Fair Lawn, NJ, 07410	
Phone: 973-636-9145		Phone: 973-636-9145	
Email(s) for Report: envirovision@optonline.net		Email(s) for Invoice: envirovision@optonline.net	
Purchase Order:		Purchase Order:	

Project Name/No: Elmwood Park Memorial HS/MS	US State where samples collected: NJ	State of Connecticut (CT) must select project location: Residential (Non-Taxable) <input type="checkbox"/>	Commercial (Taxable) <input type="checkbox"/>	Residential (Non-Taxable) <input type="checkbox"/>
EMSL LIMS Project ID: (if applicable, EMSL will provide)	PWMS ID:	State Reporting Required? Yes <input type="checkbox"/> No <input type="checkbox"/>		
Samples for Compliance? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	If Yes, for NPDES? <input type="checkbox"/> Yes <input type="checkbox"/> No	Other (Specify)	Samples Received Chilled? Yes <input type="checkbox"/> No <input type="checkbox"/>	
Samples Collected by (Check One): <input checked="" type="checkbox"/> EMSL <input type="checkbox"/> CLIENT	Client	Sampled By Signature: Jordan Pysko		
Sampled By Name: Jordan Pysko	Standard Turn-Around-Time: <input checked="" type="checkbox"/> 2 Weeks <input type="checkbox"/> 1 Week	The following TAT's are subject to Lab approval. Call lab to confirm TAT before submittal.		

Client Sample ID	Comp	Lab	Date / Time Collected	Matrix	Preservative	List Test(s) Needed (Write in test below, then check on sample line.)					Comments		
						Test 1	Test 2	Test 3	Test 4	Test 5		Test 6	Test 7
EH9U	<input checked="" type="checkbox"/>		8/19/16	W	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Found lead
EH8L	<input checked="" type="checkbox"/>		8/19/16	W	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Old Gym (APAIN)
EH7U	<input checked="" type="checkbox"/>		8/19/16	W	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Old Gym (APAIN)
EH7L	<input checked="" type="checkbox"/>		8/19/16	W	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	AUG 6 4M
						<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	AUG 6 5M

Reporting Requirements: <input type="checkbox"/> Results Only <input type="checkbox"/> Results and QC <input type="checkbox"/> Reduced Deliverables <input type="checkbox"/> Hz results EDD <input type="checkbox"/> Excel <input type="checkbox"/> Other (Describe Above)	
Method of Shipment:	
Relinquished by: Jordan Pysko	Date/Time: 8/20/16
Relinquished by: Jordan Pysko	Date/Time: 8/20/16 9:30
Received by: Jordan Pysko	Date/Time: 8/20/16 9:54

I AGREE TO ELECTRONIC SIGNATURE (By checking, I consent to signing this Chain of Custody document by electronic signature.)
 EMSL Analytical, Inc.'s Laboratory Terms and Conditions are incorporated into this Chain of Custody by reference to reference in their entirety. Submission of sample to EMSL Analytical, Inc. constitutes acceptance and acknowledgment of all terms and conditions by the customer.
1 OF 4
8/23/16 9:00 AM
Environ 08/23/16 9:00 AM
Rec. receipt 08/23

Environmental Chemistry Chain of Custody

EMSL Order Number / Lab Use Only

012109765

EMSL Analytical, Inc.
200 Rt. 130 N
Cinnaminson, NJ 08077

PHONE (800) 220-3675
EMAIL EnvChemistry@EMSL.com

EMSL ANALYTICAL, INC.

Elmwood Park Memorial HS/MS

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information. Special Instructions and/or Regulatory Requirements (Sample Specifications, Processing Methods, Limits of Detection, etc.)

Client Sample ID	Comp	Grab	Date / Time Collected	Matrix	Preservative	List Test(s) Needed (Write in test below, then check on sample line):								Comments	
						Test 1: Lead in Drinking Water	Test 2:	Test 3:	Test 4:	Test 5:	Test 6:	Test 7:	Test 8:		
EH12	<input type="checkbox"/>	<input checked="" type="checkbox"/>	8/19/21 0627	W	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Fountain
EH13	<input type="checkbox"/>	<input checked="" type="checkbox"/>	8/19/21 0627	W	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Bottle Filter
EH19	<input type="checkbox"/>	<input checked="" type="checkbox"/>	8/19/21 0629	W	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Ice Machine
EH13	<input type="checkbox"/>	<input checked="" type="checkbox"/>	8/19/21 0631	W	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Fountain
EH08	<input type="checkbox"/>	<input checked="" type="checkbox"/>	8/19/21 0633	W	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Fountain
EH05	<input type="checkbox"/>	<input checked="" type="checkbox"/>	8/19/21 0635	W	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Upper Fountain
EH06	<input type="checkbox"/>	<input checked="" type="checkbox"/>	8/19/21 0637	W	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Lower Fountain
EH04	<input type="checkbox"/>	<input checked="" type="checkbox"/>	8/19/21 0639	W	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Upper Fountain

Method of Shipment: _____

Sample Condition Upon Receipt: _____

Relinquished by: Jordan Hysko Date/Time: 8/20/21

Received by: _____ Date/Time: _____

Relinquished by: Michael Cline Date/Time: 8/20/21 9:30

Received by: _____ Date/Time: _____

Controlled Document - COC-07 Chemistry R11 02/28/2021 AGREE TO ELECTRONIC SIGNATURE (By checking, I consent to signing this Chain of Custody document by electronic signature.)

EMSL Analytical, Inc.'s Laboratory Terms and Conditions are incorporated into this Chain of Custody by reference in their entirety. Submission of samples to EMSL Analytical, Inc. constitutes acceptance and acknowledgment of all terms and conditions by Customer.

5. 6. 7. 8. 9. 10. 11. 12.

OrderID: 012109765

2 of 4

Environmental Chemistry Chain of Custody

EMSL Order Number / Lab Use Only

012109765

EMSL Analytical, Inc.
200 Rt. 130 N
Cinnaminson, NJ 08077

PHONE (800) 220-3675
EMAIL EnvChemistry2@EMSL.com



EMSL ANALYTICAL, INC.

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information
Special Instructions and/or Regulatory Requirements (Sample Specifications, Processing Methods, Limits of Detection, etc.)

Elmwood Park Memorial HS/MS

Client Sample ID	Comp	Grab	Date / Time Collected	Matrix	Preservative	List Test(s) Needed (Write in test below, then check on sample line:)										Comments	
						Test 1	Test 2	Test 3	Test 4	Test 5	Test 6	Test 7	Test 8	Test 9	Test 10		
13. EH14	<input type="checkbox"/>	<input checked="" type="checkbox"/>	8/14/21 0641	W	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Leaver fountain
14. EH03	<input type="checkbox"/>	<input checked="" type="checkbox"/>	8/14/21 0643	W	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Kitchen faucet sink
15. EH11	<input type="checkbox"/>	<input checked="" type="checkbox"/>	8/14/21 0645	W	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Fountain
16. EH11B	<input type="checkbox"/>	<input checked="" type="checkbox"/>	8/14/21 0645	W	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Bottle Filter
17. EH15	<input type="checkbox"/>	<input checked="" type="checkbox"/>	8/14/21 0647	W	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	MS OFFICE SINK
18. EH16	<input type="checkbox"/>	<input checked="" type="checkbox"/>	8/14/21 0649	W	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	MS OFFICE SINK
19. EH01	<input type="checkbox"/>	<input checked="" type="checkbox"/>	8/14/21 0651	W	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Fountain
20. EH09	<input type="checkbox"/>	<input checked="" type="checkbox"/>	8/14/21 0653	W	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Fountain

Sample Condition Upon Receipt:

Method of Shipment:

Relinquished by: Jordan Prosko	Date/Time: 8/10/21	Received by:	Date/Time:
Relinquished by: Michael Riv	Date/Time: 8-20-21	Received by:	Date/Time:

Controlled Document - C02-07 Chemistry 11.02/20/2021

AGREE TO ELECTRONIC SIGNATURE (By checking, I consent to signing this Chain of Custody document by electronic signature.)

EMSL Analytical, Inc.'s Laboratory Terms and Conditions are incorporated into this Chain of Custody by reference in their entirety. Submission of samples to EMSL Analytical, Inc. constitutes acceptance and acknowledgment of all terms and conditions by Customer.

3 OF 4

Environmental Chemistry Chain of Custody

EMSL Order Number / Lab Use Only

02109765

Elmwood Park Memorial HS/MS

EMSL Analytical, Inc.
200 Rt. 130 N
Cinnaminson, NJ 08077

PHONE: (800) 220-3675
EMAIL: EnvChemistry2@EMSL.com



EMSL ANALYTICAL, INC.

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information. Special Instructions and/or Regulatory Requirements (Sample Specifications, Processing Methods, Limits of Detection, etc.)

Client Sample ID	Comp	Grab	Date / Time Collected	Matrix	Preservative	List Test(s) Needed (Write in test below, then check on sample line.)								Comments	
						Test 1	Test 2	Test 3	Test 4	Test 5	Test 6	Test 7	Test 8		
EH10	<input type="checkbox"/>	<input checked="" type="checkbox"/>	8/14/01 0655	W	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Guidance Sink
EH02	<input type="checkbox"/>	<input checked="" type="checkbox"/>	8/14/01 0658	W	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Fountain
EH07	<input type="checkbox"/>	<input checked="" type="checkbox"/>	8/14/01 0701	W	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Fountain
EH8	<input type="checkbox"/>	<input checked="" type="checkbox"/>	8/14/01 070	W	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Blank
EH001	<input type="checkbox"/>	<input checked="" type="checkbox"/>	8/14/01 0800	W	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Sink
	<input type="checkbox"/>	<input type="checkbox"/>				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
	<input type="checkbox"/>	<input type="checkbox"/>				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
	<input type="checkbox"/>	<input type="checkbox"/>				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	

Method of Shipment: _____

Relinquished by: *Jordan Rystop* Date/Time: 8/20/01

Relinquished by: *Michael Liu* Date/Time: 8-20-01 9:30

Received by: _____ Date/Time: _____

Received by: _____ Date/Time: _____

AGREE TO ELECTRONIC SIGNATURE (By checking, I consent to signing this Chain of Custody document by electronic signature.)

EMSL Analytical, Inc.'s Laboratory Terms and Conditions are incorporated into this Chain of Custody by reference in their entirety. Submission of samples to EMSL Analytical, Inc. constitutes acceptance and acknowledgment of all terms and conditions by Customer.

4 OF 4