



**Additions and Interior Renovations to Gantner,
Gilbert, and 16th Ave. Elementary Schools
D/R Project No. 4132**

February 2, 2024

This Addendum is issued to all Contractors for the purpose of amending the requirements of the Contract Documents, as referred to and noted for the above project, and is hereby made part of said Contract Documents to the same extent as though it were originally included therein. In accordance with laws and the applicable provisions of the Contract Documents, the OWNER hereby issues this Addendum to same. The Contract Documents REQUIRE that each BIDDER acknowledge receipt of this Addendum in the space provided on the Proposal Form. This Addendum shall amend, supplement, and supersede the Contract Documents only as and to the extent explicitly stated herein.

ADDENDUM #6

A. SPECIFICATIONS

1. Spec. Section 264113, LIGHTNING PROTECTION FOR STRUCTURES, dated December 20, 2023. **Replace** with Spec. Section, 264113, LIGHTNING PROTECTION FOR STRUCTURES, dated February 2, 2024, herein attached.

B. DRAWINGS

1. NO ISSUES

C. MISCELLANEOUS

Pre-Bid RFI#4 from B&C Contractors, Inc. Dated February 1, 2024

1. 16th Ave ES: KN#13/D2.1 calls for Remove and Reinstall smart Boards at new SGI Rm 100, upon reviewing elevation marked 3C/A-10.2 indicate TV (By Owner and 2 MB only. Please clarify.
Response: Turn smart board over to owner. Install new TV supplied by owner.
2. As per Bid documents for all 3 schools TV are by Owner. Please confirm it is supply and installed by Owner. Total 16 pcs found (6+5+5)
Response: To be supplied by owner and installed by contractor.
3. As per Bid documents for all 3 schools Roof plan A-4.1 note found for Lightning Protection and indicated on E-2.00 & E2.01. Please provide Specs for this item.
Response: Specification section 264113, herein attached.
4. Gilbert ES: Dwg. C-2.0 indicates 3 light Poles to be relocated with new Concrete base & rewiring few feet apart from existing locations. There is no Electrical Site Plan issued. Please confirm existing wiring to be utilized with extension as required with new light pole base only.
Response: Contractor shall extend/modify existing branch circuits for site lighting relocation as required.



Pre-Bid RFI#4 from Vanas Construction Co., Inc. Dated February 1, 2024

1. Specification Section 11480 – Athletic Equipment was provided in Addendum #3 and makes references to wall mounted basketball backstops, basketball backboards, and basketball backboard padding. Please confirm there is no basketball equipment required for this project. If so, please advise where they are required as we cannot locate on drawings.

Response: There are no backboards, etc. The only equipment is the wall padding to be installed at the existing multi-purpose room infill area.

END OF ADDENDUM #6